



SHRIRAM INSTITUTE FOR INDUSTRIAL RESEARCH

(A unit of Shriram Scientific and Industrial Research Foundation)

19, University Road, Delhi – 110007 (India)
An ISO - 9001, 14001 & 45001 Certified Institute

Website : www.shriraminstitute.org
E-mail id : customercare@shriraminstitute.org
qad@shriraminstitute.org

TEST REPORT

NO : C1/0000409482

Issued To :

Client Code : (NODA01S5494)
SK YDECOR LAMINATES PRIVATE LTD.
F-26, SECTOR-8
NOIDA
UTTAR PRADESH-201301
Kind Attn: MR. UTSAV GARG, MANAGING
DIRECTOR

Date of issue : 20/11/2025
Job No : 2511-1-141-259
Booking No : RG2526/1/5594
Booking Date : 05/11/2025
Customer Ref No. : -
Customer Ref Dt. : 05/11/2025
Location : Laboratory

Job No- 2511-1-141-259

SAMPLE DESCRIPTION :-

ONE SAMPLE (QUANTITY: 6 PCS OF 1 MTR.X 4 INCHES) DESCRIBED AS SAMPLE OF SOFFITO PANEL , WAS RECEIVED.

"THE SAMPLING WAS NOT CARRIED OUT BY SHRIRAM INSTITUTE FOR INDUSTRIAL RESEARCH. THE SAMPLE PARTICULARS PROVIDED IN THE TEST REPORT ARE BASED ON DECLARATION BY THE CUSTOMER."

S.No.	Test	Result	Protocol adopted
1	Fire Resistance (FR)	Sample does not reaches 25 mm reference mark	ASTM D 635-22


Note : Sample does not reaches 25 mm reference mark, It is Fire Resistance.

Date of Receipt: 05.11.2025

Date of Start: 06.11.2025

Date of completion: 20.11.2025

End of Report



[Signature]
Reviewed and Authorized by
EMPLOYEE CODE:(4159)